



FF102/25

FF102/25 Ventilated Cavity Fire Barrier

Tenmat's FF102/25 Ventilated Cavity Fire Barriers are designed to reinstate fire resistance performance within external wall cavities that require permanent (open-state) ventilation in non-fire conditions.

Product Description

The FF102/25 Ventilated Cavity Fire Barrier, is manufactured from low smoke zero halogen high expansion intumescent material and is designed to reinstate fire resisting performance to external wall cavities that are required to be ventilated (open-state) in non-fire conditions.

The FF102/25 is manufactured from a rigid intumescent material allowing it to be provided in a strip format, it is also covered with a protective layer of aluminium foil for ease of handling and increased durability. In the event of a fire the FF102/25 intumescent material will expand to close the external wall cavity, providing effective fire resistance, for integrity and insulation for up to 60 minutes depending upon the construction of the external walls.

The FF102/25 is designed for use within a designed 25mm cavity, and once installed will close the remaining free air gap (in front of the 4mm cavity barrier) of 21mm.

Product Details

- CCPI Verified
- A fire rated product designed to act as an external wall cavity barrier at the junction of compartment floors, within uninsulated cavities
- Tested and proven to reinstate the fire resistance performance within “open-state” external wall cavities for periods up to 60 minutes, for both integrity and insulation to the principles of EN 1363-1 and in accordance with ASFP TGD 19 guidance
- Ventilated design – developed to allow maximum ventilation of cavities reducing the need for cavity trays or weepholes
- Suitable for “open-state” ventilated cavities up to 25mm wide
- Provided in strips of 1m long, 35mm wide and 4mm thick
- Lightweight – designed to be easily and quickly installed
- No maintenance required after installation



Approved Applications

FF102/25 "open state ventilation"

United Kingdom and European Fire Test Performance – Tested to the principles of BS EN 1363-1 and in accordance with ASFP TGD19 guidance

Inner Leaf Substrate Type (facing cavity) with Appropriate minutes Fire Rating	Outer leaf Substrate Type (facing cavity) With Appropriate Fire Resistance	Orientation	Insulation Type Within Cavity	Maximum Cavity Width (in mm)	Maximum Open State Air Gap (in mm)	Product Dimensions (thickness x height x length in mm)	Product Fire Resistance Rating	
							Integrity	Insulation
OSB/Timber Frame	Masonry	Horizontal	None	25	21	4 x 35 x 1000	60*	60*
SFS Frame with Calcium Silicate Board	Aerated Concrete Slab	Horizontal	None	25	21	4 x 35 x 1000	60	60
SFS Frame with Cement Particle Board	Aerated Concrete Slab	Horizontal	None	25	21	4 x 35 x 1000	60	60
SFS Frame with Gypsum External Weather Board	Aerated Concrete Slab	Horizontal	None	25	21	4 x 35 x 1000	60	60
SFS Frame with Calcium Silicate Board Aerated Concrete Slab	Aerated Concrete Slab	Horizontal	None	25	21	4 x 35 x 1000	60	60
Masonry Aerated Concrete Slab	Aerated Concrete Slab	Horizontal	None	25	21	4 x 35 x 1000	60	60
Blockwork Aerated Concrete Slab	Aerated Concrete Slab	Horizontal	None	25	21	4 x 35 x 1000	60	60

Fire Test Evidence:

Field of Application Report – PAR23492/01

Timber Frame inner substrate tested with min. 9mm thick OSB Sheathing Board with a minimum 35mm thick timber stud that must be in place directly behind the sheathing board in line with the cavity barrier.

For further details and guidance on the tested applications please refer to the Field of Application Report, which is available from Tenmat on request.

*The fire rating required on Timber Frame projects would typically be expected to be 30 minutes only. The fire ratings and information provided in this document and supporting fire test evidence is not intended to be a complete specification for the proposed cavity barrier and it is the responsibility of others (the Principal Designer) to ensure that the product/assembly is suitable for the intended purpose.

Fire test evidence, safety data sheets and previous versions of product information are all available upon request by contacting Tenmat, please click [here](#)



Technical Information

Colour	Silver
Finish	Foil
Storage	Dry, ambient (see Safety Data Sheet)
Weight	0.15kg
Fire Resistance	See Fire Test Evidence table.
Durability to EOTA TR024 (Intumescent/Reactive Seal)	Type X - intended for outdoor use or exposed to free weathering - rain, UV, high temperatures in summer, frost and frost-thaw in winter. ¹
European Product Declaration (EPD)	EPD in accordance with EN15804+A2 & ISO 14025 / ISO 21930 ²
Smoke Generation - BS EN 45545-2	Low Smoke Generation in intumescent material testing ³ Tenmat FF102 Results Ave. Ds(max)20 value =3 Max. limit 300 as per EN45545-2
Halogen Content	Halogen-free Tested Max. Values Fluorine = 0.0006% / 6ppm Bromine = 0.0001% / 1ppm Chlorine = 0.0007% / 7ppm Iodine = 0.0006% / 6ppm Max. limit 0.5% / 5000ppm ⁴
Working Life	60 years ⁵
Dimensional Tolerances	Thickness = 4mm Width = 35mm Length = 1000mm

The product is not subject to any warning or ban under Section 26 of the NZ Building Act 2004.



Pre Installation

The principal designer must approve the use of any cavity barrier, in conjunction with the products fire test reports, taking full account of the whole construction of the external wall systems and components, including any requirements of National Building Regulations and or NHBC Standards.

The FF102/25 demonstrates functional compliance for various National Building Codes & Regulations including Approved Document B for England & Wales, Building (Scotland) Regulations 2004, Section 2.4 Cavities and NZ Building Code Clause C3: Fire affecting areas beyond the source.

Before a Tenmat FF102/25 cavity barrier is recommended by Tenmat, the following information is required to ensure that the suggested product is considered suitable for the intended application, by Tenmat, within the construction as indicated by the client.

- Project name, location and postcode.
- Building height and use (as per ADB V1/2 2020).
- Fire resistance period/rating required. Integrity and Insulation.
- Composition and construction of external walls, both inner and outer substrates.
- Total external wall cavity size. (Maximum distance from outer face of inner substrate to inner face of inner substrate including tolerances/profiles).
- Type and thickness of cavity insulation if present.
- What ventilation gap is required horizontally?
- Are non-vented cavity barriers required vertically?
- Quantity required to complete project?
- When will materials be required?
- Name and role of person completing form.

When the above information is obtained then this can be cross referenced with the full range of Tenmat cavity barriers to ensure that the product recommended, by Tenmat, is considered suitable for consideration by the principal designer.

General considerations

Ideally the cavity barrier should be installed uninterrupted in a continuous line, the product is tested without interruptions.

The principal designer must sanction any interruptions, which may include items such as brackets, rails or battens, that may affect the continuous line of the cavity barrier. The principal designer must consider the combustibility, melting points and the shape of any interruptions, that are likely to prevent the cavity barrier performing as tested or as expected in the projects design.

If there are interruptions/obstructions that prevent the cavity barrier being fitted in a continuous line, and with sanction from the principal designer, the product may be cut with a sharp knife and tightly butted up against any obstructions and then restarted on the opposite side of the obstruction. The obstruction must not create a void which the cavity barrier can not expand into.

Intumescent cavity barriers are tested and designed to expand outwards, from the face of the intumescent material only, additional design details will be required to account for external corners.

The cavity barrier should not be penetrated by anything other than the mechanical fixings which are used to fix the cavity barrier to the building.

The cavity barrier should be installed onto a flat surface, with no gaps behind the cavity barrier, the maximum space in front of the cavity barrier should not be greater than 21mm

The Tenmat technical team should be consulted in any instance where the principal designer is uncertain as to any issues which may impede the ability of the cavity barrier to perform as expected.


Ensure the installation area is free from dust, oil and any corrosive material

Check the mounting substrate is solid and free from cracks and degradation before beginning.

Intended Use

As a cavity barrier, within external wall cavities requiring permanent (open-state) ventilation, to reinstate fire resistance performance of uninsulated cavities of up to 25mm, in fire conditions.

Installation Instructions



- Affix the product using stainless steel screws or nails at a maximum spacing of 250mm centres and max. 125mm from each end, using a countersunk screw head of minimum 6mm and maximum 11.5mm diameter head.
- Typical minimum embedment of fixing would be 25mm in timber and 50mm in concrete or alternatively the minimum stated by the fixing manufacturer.
- Tighten any fastenings until the head is just touching the product, it should not be overtightened as this may damage the strip
- When attaching a solid substrate ensure that the fixings are along the centre line of the fire barrier and the labelled side is facing out into the cavity. (So that you can read the label once the fire barrier is installed)
- If adding additional lengths, ensure they are tightly butted up against each other

Limitations

To ensure compliance to the relevant test evidence detailed within this Data Sheet, the product must be installed as per the fitting instructions by competent installers. The product must only be used in a horizontal orientation.

Maintenance

- No active maintenance required.
- Where alterations are made around the product it should be checked visually to ensure that the product is still installed as per the approved original design and fitting instructions at the time of original installation.
- Where product(s) is damaged or tampered, new product should be installed in line with installation guidance.

Storage Conditions

- See Safety Data Sheet

Tools Required

- Sharp Knife
- Measuring Tape
- Appropriate drill
- Stainless steel fixings

PPE Required

- Hand protection
- Eye protection
- Follow project site requirements

Disposal

- Outer packaging can be cleaned and recycled.
- Intumescent is non hazardous waste and is categorised as “waste accepted at landfill for non-hazardous waste” and local regulations should be followed.

Please see Safety Data Sheet for more information.

FF102/25

Tenmat Ltd.
Northbanks Industrial Park,
Irlam, Frank Perkins Way,
Greater Manchester,
M44 5EW

+44 161 872 2181
fpsales@tenmat.com

tenmat.com



Advanced materials.
tenmat.com

Tenmat warrants the materials it produces will conform to Tenmat specifications and approved drawings where applicable. It is entirely the customer's responsibility to make the final product choice and satisfy themselves of the suitability of the product for the intended application, carrying out testing where required. For construction projects, all products which the customer is intending to use on a particular project must be approved in writing by the customer's building designer, system designer or design control professional, to ensure compliance with the latest regulations.

The information contained in Tenmat data sheets is presented in good faith. Tenmat Limited makes passive fire protection product suggestions based solely upon and limited to the information made available to Tenmat. Tenmat possesses knowledge of fire test data and offers manufacturers installation advice. Within reason, Tenmat is skilled at offering opinion concerning the installations in question, and can comment on interfaces with other construction materials, but this is not a recommendation or decision. Decisions on overall building fire strategy are not made by Tenmat. Tenmat products have been tested for a wide range of construction types, and they must be only used in accordance with Tenmat test evidence. Each specific Tenmat product must be installed into a construction that matches the corresponding test report. Tenmat product performance requires safe and proper handling and correct installation.

Doc Reference: TDS-33		
Revision: 2		Date: 03/12/2025
PB: CM	CB: CT	AB: DR